

The Education Academy

505 N. Main St.

Lanoka Harbor, NJ 08734

Analytical Results for Lead

JR Henderson Labs, Inc.

123 Seaman Ave.

Beachwood, NJ 08722

732-341-1211

Lab #15083

J.R. HENDERSON LABS, INC.

123 Seaman Ave.
Beachwood, New Jersey 08722

Potable Water & Wastewater Analysis
Atomic Absorption
Gas Chromatography

(732) 341-1211
FAX (732) 505-1658
ID # 15083

State Certified
Drinking Water Laboratory
Consulting Service

The Education Academy
505 N. Main St.
Lanoka Harbor, NJ 08734

Sample Date: 6-22-22

SAMPLE #	SAMPLE LOCATION	SAMPLE TIME	ANALYTE NAME/CODE	ANALYTICAL METHOD	RESULTS UG/L	ANALYSIS DATE	ANALYSIS TIME	ACTION LEVEL UG/L
TEA-062222.1	Field Blank	07:20	LEAD/1030	200.9	<2.00	6/24/2022	21:24	15
TEA-062222.2	1st Floor Water Cooler	07:21	LEAD/1030	200.9	3.00	6/24/2022	21:48	15
TEA-062222.3	Nurse Bath Sink	07:23	LEAD/1030	200.9	<2.00	6/24/2022	21:54	15
TEA-062222.4	3rd Floor Water Cooler	07:26	LEAD/1030	200.9	2.60	6/24/2022	22:00	15
TEA-062222.5	3rd Floor Kitchen Sink	07:29	LEAD/1030	200.9	<2.00	6/24/2022	22:06	15
TEA-062222.6	2nd Floor Water Cooler	07:32	LEAD/1030	200.9	<2.00	6/24/2022	22:30	15

All samples were run undiluted (dilution factor 1) unless otherwise noted here.
UG/L=micrograms of contaminant per liter of water, equivalent to ppb (parts per billion).
< = less than

Examined By: *Margaret Ellis*
Lab Manager

Date: 6-29-22

The Education Academy
6/22/22 Lead Results

Field ID	Flushed Y/N	Laboratory sample ID	Laboratory Name	Lab Certification ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Concentration in ug/L	Reporting Limit (ug/L)	Dilution Factor	Digested (Y/N)	Qualifier
Field Blank	N	TEA-062222.1	JRH Labs	15083	6/22/2022	07:20	200.9	6/24/2022	21:24	<2.00	2.00	1	N	
1st Floor Water Cooler	N	TEA-062222.2	JRH Labs	15083	6/22/2022	07:21	200.9	6/24/2022	21:48	3.00	2.00	1	N	
Nurse Bath Sink	N	TEA-062222.3	JRH Labs	15083	6/22/2022	07:23	200.9	6/24/2022	21:54	<2.00	2.00	1	N	
3rd Floor Water Cooler	N	TEA-062222.4	JRH Labs	15083	6/22/2022	07:26	200.9	6/24/2022	22:00	2.60	2.00	1	N	
3rd Floor Kitchen Sink	N	TEA-062222.5	JRH Labs	15083	6/22/2022	07:29	200.9	6/24/2022	22:06	<2.00	2.00	1	N	
2nd Floor Water Cooler	N	TEA-062222.6	JRH Labs	15083	6/22/2022	07:32	200.9	6/24/2022	22:30	<2.00	2.00	1	N	

Chain of Custody

POTABLE WATER SAMPLING FOR LEAD CONCENTRATION SAMPLE COLLECTION FORM

CLIENT INFORMATION

Name: The Education Academy
Address: 505 N. Main St, Lanoka Harbor, NJ 08734
Client Rep: Linda Phillips 732-245-1838/609-693-3322

LAB INFORMATION

Name: JR Henderson Labs
Address: 123 Seaman Ave, Beachwood, NJ 08722
Proj.Mgr: Trevor Ellis 732-341-1211

SCHOOL/PROJECT INFORMATION

BLDG ID:				
BLDG No/Name: The Education Academy				
BLDG Address: 505 N. Main St, Lanoka Harbor, NJ 08734				
Contact Name & Numbers: Linda Phillips 732-245-1838/609-693-3322				
(0) Yr. Built:	(1) Yr. 1st Add.:	(2) Yr. 2nd Add.:	(3) Yr. 1st	(4) Yr. 2nd Mod.:

SAMPLING TEAM: FRANK PHILLIPS **DATE OF SAMPLING:** 6-22-22

SAMPLE DATA

Sample Description ID (ID must match container label)						Drinking Water Outlet Information			
Sample #	Floor	Functiona Space	IN/BY	Room Number	Sample/ Outlet Code	Sampled Outlet Location/Coordinates/number	0 Seconds	30	Time of collection (24hr)
F B						Field Blank	X		7:20 AM
						1 ST FLOOR WATER COOLER			7:21 AM
						NURSES BATHROOM SINK			7:23 AM
						3 RD FLOOR WATER COOLER			7:26 AM
						3 RD FLOOR KITCHEN SINK			7:29 AM
						2 ND FLOOR WATER COOLER			7:32 AM

All containers are pre-cleaned/ 250 ml plastic bottles preserved w HNO₃ @ pH<2 by field or to be preserved by lab

CHAIN OF CUSTODY

Relinquished By:	Date/Time:	Received By:	Date/Time:
I. <i>[Signature]</i>	6/22/22 15:44	<i>[Signature]</i>	6/22/22 15:45
II.			
III.			

Method of shipment/delivery: Fed-Ex Hand Delivery US Mail UPS Courier Other: _____

INSTRUCTIONS TO THE LABORATORY

Analyze both initial and follow up samples <input type="checkbox"/> Other: <input checked="" type="checkbox"/> Follow QAPP instructions	Lab: JR Henderson Labs 123 Seaman Ave. Beachwood, NJ 08722 Contact: Stacey Yuro	Report Results to: <input type="checkbox"/> Phone <input checked="" type="checkbox"/> Email: educationacademy@comcast.net <input type="checkbox"/> Fax
-----------------------------------------------------------------------------------------------------------------------------------------------	------------------------------------------------------------------------------------------------------------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: Provide Laboratory Data Report (LDR) Package and Chain of Custody