

The Education Academy

505 N. Main St.

Lanoka Harbor, NJ 08734

Analytical Results for Lead

JR Henderson Labs, Inc.

123 Seaman Ave.

Beachwood, NJ 08722

732-341-1211

Lab #15083

J.R. HENDERSON LABS, INC.

123 Seaman Ave.
Beachwood, New Jersey 08722

Potable Water & Wastewater Analysis
Atomic Absorption
Gas Chromatography

(732) 341-1211
FAX (732) 505-1658
ID # 15083

State Certified
Drinking Water Laboratory
Consulting Service

The Education Academy
505 N. Main St.
Lanoka Harbor, NJ 08734

SAMPLE #	SAMPLE LOCATION	SAMPLE DATE	SAMPLE TIME	ANALYTE NAME	ANALYTICAL METHOD	RESULTS UG/L	ANALYSIS DATE	ANALYSIS TIME	ACTION LEVEL UG/L
25-2243.1	Field Blank	5/1/2025	07:40	LEAD	200.8	<0.30	5/5/2025	09:02	15
25-2243.2	Basement Water Cooler	5/1/2025	07:46	LEAD	200.8	<0.30	5/5/2025	09:11	15
25-2243.3	1st Floor Water Cooler	5/1/2025	07:50	LEAD	200.8	<0.30	5/5/2025	09:14	15
25-2243.4	1st Floor Nurse's Office Sink	5/1/2025	07:52	LEAD	200.8	0.32	5/5/2025	09:17	15
25-2243.5	2nd Floor Water Cooler	5/1/2025	07:55	LEAD	200.8	0.68	5/5/2025	09:20	15
25-2243.6	2nd Floor Kitchen Sink	5/1/2025	07:58	LEAD	200.8	0.62	5/5/2025	09:29	15

All samples were run undiluted (dilution factor 1) unless otherwise noted here.
UG/L=micrograms of contaminant per liter of water, equivalent to ppb (parts per billion).
< = less than
MRL = Minimum Reporting Limit
Lead Method 200.8-MRL 0.3

Examined By: *Margaret Ellis*
Lab Manager

Date: 5-7-25

The Education Academy
Lead Results

Field ID	Flushed Y/N	Laboratory sample ID	Laboratory Name	Lab Certification ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Concentration in ug/L	Reporting Limit (ug/L)	Dilution Factor	Digested (Y/N)	Qualifier
Field Blank	N	25-2243.1	JRH Labs	15083	5/1/2025	07:40	200.8	5/5/2025	09:02	<0.30	0.30	1	N	
Basement Water Cooler	N	25-2243.2	JRH Labs	15083	5/1/2025	07:46	200.8	5/5/2025	09:11	<0.30	0.30	1	N	
1st Floor Water Cooler	N	25-2243.3	JRH Labs	15083	5/1/2025	07:50	200.8	5/5/2025	09:14	<0.30	0.30	1	N	
1st Floor Nurse's Office Sink	N	25-2243.4	JRH Labs	15083	5/1/2025	07:52	200.8	5/5/2025	09:17	0.32	0.30	1	N	
2nd Floor Water Cooler	N	25-2243.5	JRH Labs	15083	5/1/2025	07:55	200.8	5/5/2025	09:20	0.68	0.30	1	N	
2nd Floor Kitchen Sink	N	25-2243.6	JRH Labs	15083	5/1/2025	07:58	200.8	5/5/2025	09:29	0.62	0.30	1	N	

Chain of Custody

POTABLE WATER SAMPLING FOR LEAD CONCENTRATION SAMPLE COLLECTION FORM

CLIENT INFORMATION

Name: The Education Academy
Address: 505 N. Main St., Lanoka Harbor, NJ 08734
Client Rep: Frank Phillips 908-489-4189

LAB INFORMATION

Name: JR Henderson Labs, Inc.
Address: 123 Seaman Ave., Beachwood, NJ 08722
Lab Mgr.: Trevor Ellis

SCHOOL/PROJECT INFORMATION

Bldg : The Education Academy
Bldg No:
Bldg Address: 505 N. Main St., Lanoka Harbor, NJ 08734
Contact Name & Number: Frank Phillips 908-489-4189

SAMPLE DATA - ID & Location must match container label

Office Use Leave Blank	Sample ID	Sampled Outlet Location	Date	Time (24hr)	First Draw	Flushed
	25-2243.1	Field Blank	5/1/25	7:40AM	X	
	25-2243.2	BASEMENT WATER COOLER	5/1/25	7:46AM	X	
	25-2243.3	1ST FLOOR WATER COOLER	5/1/25	7:50AM	X	
	25-2243.4	SINK-1ST FLOOR-NURSES OFFICE	5/1/25	7:52AM	X	
	25-2243.5	2ND FLOOR WATER COOLER	5/1/25	7:55AM	X	
	25-2243.6	SINK-2ND FLOOR-KITCHEN	5/1/25	7:58AM	X	

All containers are pre-cleaned/ 250 ml plastic bottles preserved w/ HNO₃ @ pH<2 to be preserved by lab

CHAIN OF CUSTODY

Relinquished By:	Date/Time:	Received By:	Date/Time:
<i>Frank Phillips</i>	5/1/25 9:00AM	<i>Stacey Yuro</i>	5/1/25 09:01

Method of shipment/delivery: ☐ Fed-Ex ☒ Hand Delivery ☐ Other: _____

INSTRUCTIONS TO THE LABORATORY

Analyze both initial and follow up samples ☐ Other: ☒ Follow QAPP instructions	Lab: JR Henderson Labs 123 Seaman Ave. Beachwood, NJ 08722 Contact: Stacey Yuro syuro@henderson-labs.com	Report Results to: ☐ Phone ☒ Email: educationacademy@comcast.net
---	--	---

Comments: Provide Laboratory Data Report (LDR) Package and Chain of Custody